



REQUEST FOR QUOTATION
PR NO. 26-09-1136
SETEMBER 25, 2026

The **Valenzuela Medical Center (VMC)** through its **Bids and Awards Committee (BAC)** intends to procure the **“PROCUREMENT OF REPLACEMENT AND INSTALLATION OF UNINTERRUPTED POWER SUPPLY (UPS) AND ADDITIONAL ISOLATION TRANSFORMER FOR 3D/4D ULTRASOUND MACHINE WITH ELASTOGRAPHY COMPATIBLE TO BRAND/MODEL”** for the Engineering and Facilities Management Section in accordance with Section 34.1 (Small Value Procurement) of the Implementing Rules and regulations of the Republic Act No. 12009.

Please send your **price offer** for the items listed below duly signed by you or your authorized representative not later than September 30, 2026. The BAC reserves the right to accept, reject & waive defects in the canvass.

ITEM NO.	QTY	UNIT	ARTICLES	UNIT	TOTAL COST
				PRICE	
			Replacement and Installation		
			3D/4D ULTRASOUND MACHINE WITH ELASTOGRAPHY		
			Brand: GE/Voluson S10 Expert		
			SN: VSX802742		
1	1	unit	UPS, 3KVA	65,000.00	65,000.00
			Input		
			-Rated Voltage: 208 / 220 / 230 / 240 Vac		
			-Voltage Range: 176 ~ 280 Vac (no derating), 280 ~ 300 Vac (derating 50%)		
			-Frequency: 40 ~ 70 Hz (auto-sense)		
			-Power factor: ≥ 0.99		
			-Bypass voltage range: -25% ~ +15% (settable)		
			Output		
			-208 / 220 / 230 / 240 Vac (settable)		
			-Voltage regulation: ± 1%		
			-Frequency: 55 ~ 65 Hz (synchronized range),		
			Battery mode: 50 / 60 ± 0.1 Hz		
			-Waveform: Sinusoidal		
			-Harmonic distortion: ≤ 2% with linear load, ≤ 5% with non-linear load		
			-Transfer time: Mains mode to battery mode - 0 ms		
			-Overload capability: 105% ~ 125%: transfer to		
			bypass in 1 min; 125% ~ 150%: transfer to bypass		
			in 30 s; > 150%: transfer to bypass in 300 ms		
			Efficiency		
			Mains mode: ≥ 92%		
			Battery mode: ≥ 87%		
			Batteries		
			-Inbuilt battery / DC voltage: 12V / 9 Ah x 6 (72V) or		
			12V / 7 Ah x 8 (96V)		
			Charging current (max.): Standard model: 1 A		
			-Recharge time: Standard model - 90% capacity		
			restored in 3 hours		
			Others		

“PHIC Accredited Healthcare Provider”
“Valenzuela Medical Center...Where your health matters most”



Address: **Padrigal St., Karuhatan, Valenzuela City, 1441**
Telephone Nos: **8294-6711 to 17**
Director's Office Direct Line: **8291-4259**
Email Address: **valgen_hosp@yahoo.com**
Website: **https://vmc.doh.gov.ph/**



Republic of the Philippines
Department of Health
Metro Manila Center for Health Development
VALENZUELA MEDICAL CENTER




BAGONG PILIPINAS

			-Protections: Overload, surge, short circuit, battery		
			low voltage, battery overcharge, over-temperature		
			-Noise level: ≤ 50 dB (1m)		
2	1	unit	3KVA, ISO	30,000.00	30,000.00
			Input Voltage: AC 110/120V/130V/200V/220V/230V/ 240/250V etc. (optional)		
			Output voltage: C 110/120V/130V/200V/220V/230V/ 240/250V etc. (optional)		
			Frequency: 50Hz/60Hz		
			Efficiency: >95%		
			Insulation resistance: >2MΩ		
			Withstand voltage: 1500V/min.		
			Cooling: Natural/forced air		
			Noise: <55dB		
			Working Mode: Continuous		
			Others:		
			IP21 enclosure(indoor)		
			Non-flammable and non-explosive		
			Completion of Delivery:		
			30 Calendar days upon receipt of approved Job Order		
			Warranty: One (1) year for parts and services		
			***** nothing follows *****		
				TOTAL	95,000.00

A copy of your UPDATED legal requirements (Certificate of Registration from BIR, SEC/DTI, Business/Mayor's Permit with Official Receipt, Platinum PhilGEPS Certificate, Tax Clearance, ITR 2025, Notarized Hard Copy of Omnibus Sworn Statement, and Brochure (if applicable)) is also required to be submitted along with your quotation/proposal.

Quotations may be submitted manually at the office of the BAC Secretariat, BAC Office, Valenzuela Medical Center, Padrigal St., Karuhatan, Valenzuela City., through facsimile (telefax no. 2944625) or email to vmc_bac2026@yahoo.com. For any clarification, you may call Mr. Lester John Jake R. Divino at telephone no. 294-46-25 or via email at vmc_bac2026@yahoo.com.


LIGAYA E. UBALDE, MPA
Head, BAC Secretariat / Procurement

"PHIC Accredited Healthcare Provider"
"Valenzuela Medical Center...Where your health matters most"



Address: Padrigal St., Karuhatan, Valenzuela City, 1441
Telephone Nos: 8294-6711 to 17
Director's Office Direct Line: 8291-4259
Email Address: valgen_hosp@yahoo.com
Website: <https://vmc.doh.gov.ph/>